

Customer name: UNIVERSAL SERTİFİKASYON VE GÖZETİM HİZMETLERİ TİCARET LTD.ŞTİ.
Address: Yukarı Dudullu Mahallesi, KEYAP E2 No:84, 34775 Dudullu Organize Sanayi Bölgesi/Ümraniye/İstanbul
Buyer name: NARKONTEKS TEKSTİL İTH. İHR. SAN VE TİC. A.Ş. .
Contact Person: SUAT KAÇMAZ
Order No: -
Article No: -
Name and identity of test item: Blue surgical gown
The date of receipt of test item: 02.07.2020
Re-submitted/re-confirmation date: -
Date of test: 02.07.2020-13.07.2020
Remarks: -
Sampling: The results given in this report belong to the received sample by vendor.
End-Use: -
Care Label: Not specified.
Number of pages of the report: 7



Date
13.07.2020

Customer Representative
Servin ALPSEVEN

Head of Testing Laboratory
Sevim A. RAZAK

This report shall not be reproduced other than in full except with the permission of the laboratory.
Testing reports without signature and seal are not valid.


**EKOTEKS LABORATUVAR ve GÖZETİM
HİZMETLERİ A.Ş.**

20022522-
ing

07-20

REQUIRED TESTS	RESULT	COMMENTS
MICROBIOLOGICAL TEST		
Microbial Cleanliness (Bioburden)	P	
Wet-Bacterial Penetration	P	
Dry- Bacterial Penetration	P	
PHYSICAL PROPERTIES TESTS		
Tensile Stregth / Dry	P	
Tensile Stregth / Wet	P	
Bursting Strength / Dry	P	
Bursting Strength / Wet	P	
P: Pass F: Fail R: Refer to retailer technologist. Test results were evaluated according to EN 13795-1:2019 Standard Performance Properties Critical Sample Group limit values (Table 1)		

REMARK: Original samples are kept for 3 months and all technical records are kept for 5 years unless otherwise specified. If requested, measurement uncertainty will be reported. But unless otherwise specified, measurement uncertainty is not considered while stating compliance with specification or limit values. The reported uncertainty is based on a standard uncertainty multiplied by a coverage factor $k=2$, providing a level of confidence of approximately 95 %. Tests marked (*) in this report are not included in the accreditation schedule.



This report shall not be reproduced other than in full except with the permission of the laboratory.
Testing reports without signature and seal are not valid.

TEST RESULTS

Surgical clothing and drapes - Requirements and test methods – Part 1: Surgical drapes and gowns EN 13795-1 :2019

MICROBIAL CLEANLINESS (Bioburden)

Test Metod: EN ISO 11737-1:2018 /TS EN ISO 11737-1 :2018 (*)

The sample is put in extraciton liquid after shaking well after shaking well (250 rpm,5 min), inoculated on the suitable agar.The plates are incubated for 3 days at 30 ± 1 ° C for 72 hours, and 7 days at (20 to 25) °C for TSA and SDA plates respectively. Total microoragnisms counts are calculated.

	<u>RESULTS</u>	<u>REQUIREMENT</u>
Microbial cleanliness (cfu/g)	194 cfu/100 cm ²	≤300 cfu/100 cm ²

*cfu= Colony forming unit.

TEST RESULTS

WET-BACTERIAL PENETRATION

Test Method: BS EN 22610: 2006 (Surgical drapes, garments and fresh air clothes used as medical devices for patients, hospital staff and equipment - Test method for determination of resistance to wet bacterial permeability) (*)

A test sample is placed on the agar plate on a rotating disc. Bacteria carrier material and coating film are placed on the test sample and all parts are fixed on the disk. A finger is placed on the test sample to apply a certain force ($3N \pm 0.02$). The finger moves on the test sample over the entire surface of the agar within 15 minutes. 5 studies are carried out for 15 minutes. 6. The study is repeated by inverting the sample.

Sample amount:	5 pieces 25x25cm2
Carrier Material:	30 µm thin, 25x25cm2 Polyurethane Film
Coating Material:	25x25cm2 HDPE Film
Microorganism:	Staphylococcus aureus ATCC 29213
Bacterial Concentration (kob / ml):	2×10^5 kob / ml
Incubation Conditions:	(36 ± 1) ° C 48 hours

RESULTS			
Number of Populating Bacteria (cfu)		Penetration Rate	
X_1	0	R_{CUM1}	0
X_2	0	R_{CUM2}	0
X_3	0	R_{CUM3}	0
X_4	82	R_{CUM4}	0,12
X_5	93	R_{CUM5}	0,26
Z	479		
T		654	

X_1 X_5 : Number of colonies growing in 5 parallel petri in the same sample
 Z : number of colonies growing in the sixth petri dish
 T : $X_1 + X_2 + X_3 + X_4 + X_5 + Z$

$R_{CUM1} = X_1/T$
 $R_{CUM2} = (X_2 + X_1)/T$
 $R_{CUM3} = (X_3 + X_2 + X_1)/T$
 $R_{CUM4} = (X_4 + X_3 + X_2 + X_1)/T$
 $R_{CUM5} = (X_5 + X_4 + X_3 + X_2 + X_1)/T$

BARRIER INDEX (I_B)		
	Result	Expected value (*)
I_B	5,6	$\geq 2,8$

$I_B = 6 - (CUM1 + CUM2 + CUM3 + CUM4 + CUM5)$

* EN 13795-1:2019 Surgical gowns and drapes - Requirements and test methods are evaluated according to Table-1.

**EKOTEKS LABORATUVAR ve GÖZETİM
HİZMETLERİ A.Ş.**

20022522-
ing

07-20

TEST RESULTS

Test Method: ISO 22612: 2005 (Clothing for protection against infectious agents - Test method for resistance to dry microbial penetration)

Samples and containers are sterilized. Agar plates are placed in each container. Samples are placed aseptically in the apparatus. The covers are closed. After making a pot in the sample with the piston, the pistons are removed and $0.5 \text{ g} \pm 0.1 \text{ g}$ are added to five samples from the powder contaminated with bacteria and the six to the non-contaminated powder. Then all openings are closed with a plastic bag. The device is operated to give 20,800 vibrations per minute. The test time is 30 minutes. After the test is over, all agar plates are incubated at 35°C for 24 hours.

Sample amount:	6 pieces 20x20 cm ²
Mikroorganism:	<i>Bacillus subtilis</i> ATCC 9372
Bacterial concentration (cfu/ml):	1×10^8
Incubation conditions:	35°C / 24 hours
RESULTS	
Number of Population Bacteria (cfu)	
1	1
2	0
3	0
4	2
5	0
6 (Control)	0
Total	3
Logarithm	0,47
EVALUATION	
Result	Class (*)
$\log \leq 1$	3
* EN 14126: 2003 Protective Clothing - Performance Properties and Test Methods of Protective Clothing Against Infectious Agents are evaluated according to Table-4.	
Sınıf	Penetrasyon (log kob)
3	≤ 1
2	$1 < \log kob \leq 2$
1	$2 < \log kob \leq 3$
* EN 13795-1:2019 Surgical gowns and drapes - Requirements and test methods are evaluated according to Table-1.	
RESULT	
Result (cfu/g)	Expected Value
3 cfu/g	$\leq 300 \text{ cfu/g}$

Gen.f136-2/03

**EKOTEKS LABORATUVAR ve GÖZETİM
HİZMETLERİ A.Ş.**

20022522-
ing

07-20

TEST RESULTS

TENSILE STRENGTH; EN 29073-3:1996 (*)

Instron 5969 (Load: 5 kN), Strip Method.

Speed: 100 mm/min \pm 10, Gauge length 200 mm.

Pre-load was not applied. Without wetting samples.

The average results are given for width and length direction of four samples

Performed in the conditioned room (20 \pm 2°C-65% \pm 4).

Dry ;

	<u>RESULT</u>
Width	75.6 N
Length	31.7 N

REQUIREMENT

\geq 20N (Dry)

\geq 20N (Dry)

TENSILE STRENGTH; EN 29073-3:1996 (*)

Instron 5969 (Load: 5 kN), Strip Method.

Speed: 100 mm/min \pm 10, Gauge length 200 mm.

Pre-load was not applied. With wetting samples.

The average results are given for width and length direction of four samples

Performed in the conditioned room (20 \pm 2°C-65% \pm 4).

Wet ;

	<u>RESULT</u>
Width	73.3 N
Length	31.1 N

REQUIREMENT

\geq 20N (Wet)

\geq 20N (Wet)

BURSTING STRENGTH;; ISO 13938-1:1999

SDL ATLAS M229 tester. Test area: 30.5 mm diameter

The average results are given of five samples.

Performed in the conditioned room (20 \pm 2°C-65% \pm 4).

	<u>RESULT</u>
Dry ;	109.1 kPa

REQUIREMENT

\geq 40 kPa (Dry)

Height at Burst*	14.9 mm
------------------	---------

**EKOTEKS LABORATUVAR ve GÖZETİM
HİZMETLERİ A.Ş.**

20022522-
ing

07-20

TEST RESULTS

BURSTING STRENGTH;; ISO 13938-1:1999

SDL ATLAS M229 tester. Test area: 30.5 mm diameter

The average results are given of five samples.

Performed in the conditioned room (20±2°C-65%±4).

Wet ; **RESULT**
111.5 kPa

REQUIREMENT
≥ 40 kPa (Wet)

Height at Burst* 13.6 mm